



Subtract 3-5/8" from body/row length (A) and body/row length (B) to simplify installation. Luminaire needs to be installed next to support blocking. NOTE: Tolerances on dimensions are +/- 1/16". Please contact factory for dimensions of tailored luminaires with non-90° angles.



3/4"




Slowly swing down back plates. CAUTION: Do not twist back plate when swinging down - it will come out of the support extrusion. Note that the screw shown is the pivot point and the back plate can be slid a few inches either way for ease of access to the driver space.


Note: All power connections to be installed to local/national codes by a Certified Electrician.



Refer to threads and feed hole locations above before connecting luminaire wires.




A. Standard installation. Remove conduit plate from luminaire. Remove jam nut from conduit then insert wires and connector through feed hole. Secure conduit with jam nut.



Open optional splice box door to access wiring.


Run power cable through knock-out. Make electrical connection. Secure conduit on to splice box with jam nut and close splice box door.



On both ends of the luminaire, install 1/4" washers (by others) and 1/4"-20 nuts (by others) onto 1/4"-20 threaded rod (by others).

blocking (by others)


Finelite, Inc. • 30500 Whipple Road • Union City, CA 94587-1530 • (510) 441-1100 • Fax: (510) 441-1510 • www.finelite.com



2017 FINELITE, INC. ALL RIGHTS RESERVED. Form 98304 V3. 02/17

2

0



Note: All power connections to be installed to

local/national codes by a Certified Electrician.

Finelite, Inc. • 30500 Whipple Road • Union City, CA 94587-1530 • (510) 441-1100 • Fax: (510) 441-1510 • www.finelite.com


D727,551 S 550 S, ,554 S;


FINELITE[®] **Better Lighting**


2017 FINELITE, INC. ALL RIGHTS RESERVED. Form 98304 V3. 02/17

3


0









Fasten all luminaires to the wall with drywall screws (by others) through the flange into blocking.



Step 17



Note: All power connections to be installed to local/national codes by a Certified Electrician.



Install the "mud guard" cardboard inserts (provided) to help prevent spackle from getting

4